## SIEMENS

## Data sheet

## 6ES7317-2EK14-0AB0



SIMATIC S7-300 CPU 317-2 PN/DP, Central processing unit with 1 MB work memory, 1st interface MPI/DP 12 Mbit/s, 2nd interface Ethernet PROFINET, with 2-port switch, Micro Memory Card required

General information	
HW functional status	01
Firmware version	V3.2
Product function	
Isochronous mode	Yes; Via PROFIBUS DP or PROFINET interface
Engineering with	
<ul> <li>Programming package</li> </ul>	STEP 7 V5.5 or higher
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	20.4 V
permissible range, upper limit (DC)	28.8 V
external protection for power supply lines (recommendation)	2 A min.
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Repeat rate, min.	1 s
Input current	
Current consumption (rated value)	750 mA
Current consumption (in no-load operation), typ.	150 mA
Inrush current, typ.	4 A
²t	1 A <sup>2</sup> ·s
Power loss	
Power loss, typ.	4.65 W
Memory	
Work memory	
integrated	1 024 kbyte
• expandable	No
Load memory	
Plug-in (MMC)	Yes
<ul> <li>Plug-in (MMC), max.</li> </ul>	8 Mbyte
<ul> <li>Data management on MMC (after last programming), min.</li> </ul>	10 a
Backup	
• present	Yes; Guaranteed by MMC (maintenance-free)
without battery	Yes; Program and data
CPU processing times	
for bit operations, typ.	0.025 µs
for word operations, typ.	0.03 µs
for fixed point arithmetic, typ.	0.04 µs
for floating point arithmetic, typ.	0.16 µs
CPU-blocks	

Number of blocks (total)	2 048; (DBs, FCs, FBs); the maximum number of loadable blocks can be reduced by the MMC used.
DB	
• Number, max.	2 048; Number range: 1 to 16000
• Size, max.	64 kbyte
FB	
Number, max.	2 048; Number range: 0 to 7999
• Size, max.	64 kbyte
FC	
Number, max.	2 048; Number range: 0 to 7999
• Size, max.	64 kbyte
OB	
• Size, max.	64 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	1; OB 1
<ul> <li>Number of time alarm OBs</li> </ul>	1; OB 10
<ul> <li>Number of delay alarm OBs</li> </ul>	2; OB 20, 21
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	4; OB 32, 33, 34, 35
<ul> <li>Number of process alarm OBs</li> </ul>	1; OB 40
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3; OB 55, 56, 57
<ul> <li>Number of isochronous mode OBs</li> </ul>	1; OB 61 - isochronous mode is possible either on DP or PROFINET IO (not
	simultaneously)
<ul> <li>Number of startup OBs</li> </ul>	1; OB 100
<ul> <li>Number of asynchronous error OBs</li> </ul>	6; OB 80, 82, 83, 85, 86, 87 (OB83 only for PROFINET IO)
<ul> <li>Number of synchronous error OBs</li> </ul>	2; OB 121, 122
Nesting depth	
<ul> <li>per priority class</li> </ul>	16
additional within an error OB	4
Counters, timers and their retentivity	
S7 counter	
Number	512
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	511
— preset	Z 0 to Z 7
Counting range	
— adjustable	Yes
— lower limit	0
— upper limit	999
IEC counter	
• present	Yes
• Туре	SFB
Number	Unlimited (limited only by RAM capacity)
S7 times	
Number	512
Retentivity	
— adjustable	Yes
— lower limit	0
— upper limit	511
— preset	No retentivity
Time range	
— lower limit	10 ms
— upper limit	9 990 s
IEC timer	
• present	Yes
• Туре	SFB
Number	Unlimited (limited only by RAM capacity)
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	256 kbyte
Flag	
• Size, max.	4 096 byte

• Potontivity available	Vos: From MP.0 to MP.4.005
Retentivity available	Yes; From MB 0 to MB 4 095
Retentivity preset	MB 0 to MB 15
Number of clock memories	8; 1 memory byte
Data blocks	Vee vie een sekin menertu en DD
Retentivity adjustable	Yes; via non-retain property on DB
Retentivity preset	Yes
Local data	
per priority class, max.	32 768 byte; Max. 2048 bytes per block
Address area	
I/O address area	
Inputs	8 192 byte
Outputs	8 192 byte
of which distributed	
— Inputs	8 192 byte
— Outputs	8 192 byte
Process image	
Inputs	8 192 byte
Outputs	8 192 byte
<ul> <li>Inputs, adjustable</li> </ul>	8 192 byte
Outputs, adjustable	8 192 byte
<ul> <li>Inputs, default</li> </ul>	256 byte
Outputs, default	256 byte
Subprocess images	
<ul> <li>Number of subprocess images, max.</li> </ul>	1; With PROFINET IO, the length of the user data is limited to 1600 bytes
Digital channels	
Inputs	65 536
— of which central	1 024
Outputs	65 536
— of which central	1 024
Analog channels	
• Inputs	4 096
— of which central	256
Outputs	4 096
— of which central	256
Hardware configuration	200
Number of expansion units, max.	3
Number of DP masters	5
	4
• integrated	1
• via CP	4
Number of operable FMs and CPs (recommended)	
• FM	8
• CP, PtP	8
• CP, LAN	10
Rack	
Racks, max.	4
Modules per rack, max.	8
Time of day	
Clock	
<ul> <li>Hardware clock (real-time)</li> </ul>	Yes
<ul> <li>retentive and synchronizable</li> </ul>	Yes
Backup time	6 wk; At 40 °C ambient temperature
<ul> <li>Deviation per day, max.</li> </ul>	10 s; Typ.: 2 s
<ul> <li>Behavior of the clock following POWER-ON</li> </ul>	Clock continues running after POWER OFF
<ul> <li>Behavior of the clock following expiry of backup period</li> </ul>	the clock continues at the time of day it had when power was switched off
Operating hours counter	
Number	4
Number/Number range	0 to 3
Range of values	0 to 2^31 hours (when using SFC 101)
Granularity	1 h
retentive	Yes; Must be restarted at each restart

Clock synchronization	
Clock synchronization	Vac
supported     to MRL moster	Yes
• to MPI, master	
• to MPI, slave	Yes
• to DP, master	Yes; With DP slave only slave clock
• to DP, slave	Yes
• in AS, master	Yes
• in AS, slave	Yes
on Ethernet via NTP	Yes; As client
Digital inputs	
Number of digital inputs	0
Digital outputs	
Number of digital outputs	0
Analog inputs	
Number of analog inputs	0
Analog outputs	
Number of analog outputs	0
Interfaces	
Number of industrial Ethernet interfaces	1; 2 ports (switch) RJ45
Number of PROFINET interfaces	1; 2 ports (switch) RJ45
Number of RS 485 interfaces	1; Combined MPI / PROFIBUS DP
Number of RS 422 interfaces	0
1. Interface	
Interface type	Integrated RS 485 interface
Isolated	Yes
Interface types	
• RS 485	Yes
Output current of the interface, max.	200 mA
Protocols	200 11/4
• MPI	Yes
PROFIBUS DP master	Yes
PROFIBUS DP slave	
	Yes
Point-to-point connection	No
MPI	40 MH:#/a
Transmission rate, max.	12 Mbit/s
Services	Ver
— PG/OP communication	Yes
- Routing	Yes
— Global data communication	Yes
- S7 basic communication	Yes
— S7 communication	Yes
— S7 communication, as client	No; but via CP and loadable FB
— S7 communication, as server	Yes
PROFIBUS DP master	
Transmission rate, max.	12 Mbit/s
<ul> <li>Number of DP slaves, max.</li> </ul>	124
Services	
— PG/OP communication	Yes
— Routing	Yes
<ul> <li>Global data communication</li> </ul>	No
<ul> <li>— S7 basic communication</li> </ul>	Yes; I blocks only
— S7 communication	Yes
- S7 communication, as client	No
— S7 communication, as server	Yes
— Equidistance	Yes
— Isochronous mode	Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS DP or PROFINET IO
- SYNC/FREEZE	Yes
<ul> <li>Activation/deactivation of DP slaves</li> </ul>	Yes
<ul> <li>— Number of DP slaves that can be simultaneously</li> </ul>	8
activated/deactivated, max.	

Direct data systems (also to start	Vac: as subscriber
<ul> <li>Direct data exchange (slave-to-slave communication)</li> </ul>	Yes; as subscriber
— DPV1	Yes
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
User data per DP slave	
— Inputs, max.	244 byte
- Outputs, max.	244 byte
PROFIBUS DP slave	
Transmission rate, max.	12 Mbit/s
automatic baud rate search	Yes; only with passive interface
Address area, max.	32
User data per address area, max.	32 byte
Services	
— PG/OP communication	Yes
- Routing	Yes; Only with active interface
— Global data communication	No
— S7 basic communication	No
- S7 communication	Yes
— S7 communication	No
— S7 communication, as crient	Yes; Connection configured on one side only
	Yes
<ul> <li>Direct data exchange (slave-to-slave communication)</li> </ul>	
— DPV1	No
Transfer memory	
— Inputs	244 byte
— Outputs	244 byte
2. Interface	
Interface type	PROFINET
Isolated	Yes
automatic detection of transmission rate	Yes; 10/100 Mbit/s
Autonegotiation	Yes
Autocrossing	Yes
Change of IP address at runtime, supported	Yes
Interface types	
• RJ 45 (Ethernet)	Yes
Number of ports	2
integrated switch	Yes
Protocols	
• MPI	No
PROFINET IO Controller	Yes; Also simultaneously with IO-Device functionality
PROFINET IO Device	Yes; Also simultaneously with IO Controller functionality
PROFINET CBA	Yes
PROFIBUS DP master	No
PROFIBUS DP slave	No
Open IE communication	Yes; Via TCP/IP, ISO on TCP, and UDP
Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Transmission rate, max.	100 Mbit/s
Services	
— PG/OP communication	Yes
— Routing	Yes
— S7 communication	Yes; with loadable FBs, max. configurable connections: 16, max. number of
— S7 communication — Isochronous mode	instances: 32
	Yes; OB 61; isochronous mode can only be used alternatively on PROFIBUS DP or PROFINET IO
— IRT	Yes
— Shared device	Yes
— Prioritized startup	Yes
<ul> <li>— Number of IO devices with prioritized startup, max.</li> </ul>	32

- Number of connectable IO Devices, max.	128
— Of which IO devices with IRT, max.	64
— of which in line, max.	64
— Number of IO Devices with IRT and the option "high	128
flexibility"	
— of which in line, max.	61
- Number of connectable IO Devices for RT, max.	128
— of which in line, max.	128
<ul> <li>Activation/deactivation of IO Devices</li> </ul>	Yes
- Number of IO Devices that can be simultaneously	8
activated/deactivated, max. — IO Devices changing during operation (partner	Yes
ports), supported	
— Number of IO Devices per tool, max.	8
— Device replacement without swap medium	Yes
— Send cycles	250 μs, 500 μs,1 ms; 2 ms, 4 ms (not in the case of IRT with "high flexibility" option)
— Updating time	250 μs to 512 ms (depending on the operating mode, see Manual "S7-300 CPU 31xC and CPU 31x, technical Data" for more details)
Address area	
— Inputs, max.	8 kbyte
— Outputs, max.	8 kbyte
— User data consistency, max.	1 024 byte
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Routing	Yes
— S7 communication	Yes; with loadable FBs, max. configurable connections: 16, max. number of
	instances: 32
— Isochronous mode	No
— IRT	Yes
- PROFlenergy	Yes; With SFB 73 / 74 prepared for loadable PROFlenergy standard FB for I-Device
— Shared device	Yes
<ul> <li>— Number of IO Controllers with shared device, max.</li> </ul>	2
Transfer memory	
— Inputs, max.	1 440 byte; Per IO Controller with shared device
— Outputs, max.	1 440 byte; Per IO Controller with shared device
Submodules	
— Number, max.	64
— User data per submodule, max.	1 024 byte
PROFINET CBA	
acyclic transmission	Yes
cyclic transmission	Yes
Open IE communication	
Number of connections, max.	16
Local port numbers used at the system end	0, 20, 21, 23, 25, 80, 102, 135, 161, 443, 8080, 34962, 34963, 34964, 65532, 65533, 65534, 65535
Keep-alive function, supported	Yes
Protocols	
PROFIsafe	No
Redundancy mode	
Media redundancy	
— Switchover time on line break, typ.	200 ms; PROFINET MRP
<ul> <li>— Number of stations in the ring, max.</li> </ul>	50
Open IE communication	
• TCP/IP	Yes; via integrated PROFINET interface and loadable FBs
- Number of connections, max.	16
<ul> <li>— Data length for connection type 01H, max.</li> </ul>	1 460 byte
<ul> <li>— Data length for connection type 11H, max.</li> </ul>	32 768 byte
- several passive connections per port, supported	Yes
ISO-on-TCP (RFC1006)	Yes; via integrated PROFINET interface and loadable FBs
- Number of connections, max.	16

	22 769 byto
<ul> <li>— Data length, max.</li> <li>● UDP</li> </ul>	32 768 byte
	Yes; via integrated PROFINET interface and loadable FBs 16
- Number of connections, max.	
— Data length, max. Web server	1 472 byte
	Yes
supported	
User-defined websites	Yes 5
Number of HTTP clients	5
communication functions / header	Vaa
PG/OP communication	Yes
Data record routing Global data communication	Yes
	Yes
supported	8
<ul> <li>Number of GD loops, max.</li> <li>Number of GD packets, max.</li> </ul>	8
•	o 8
Number of GD packets, transmitter, max.	8
Number of GD packets, receiver, max.	
<ul> <li>Size of GD packets, max.</li> <li>Size of GD packet (of which consistent) max</li> </ul>	22 byte
<ul> <li>Size of GD packet (of which consistent), max.</li> <li>S7 basic communication</li> </ul>	22 byte
	Yes
<ul> <li>supported</li> <li>User data per job, max.</li> </ul>	76 byte
<ul> <li>User data per job (of which consistent), max.</li> </ul>	76 byte; 76 bytes (with X_SEND or X_RCV); 64 bytes (with X_PUT or X_GET
	as server)
S7 communication	
supported	Yes
• as server	Yes
• as client	Yes; via integrated PROFINET interface and loadable FB or via CP and
	loadable FB
<ul> <li>User data per job, max.</li> </ul>	See online help of STEP 7 (shared parameters of the SFBs/FBs and of the SFCs/FCs of S7 Communication)
S5 compatible communication	
supported	Yes; via CP and loadable FC
communication functions / PROFINET CBA (with set target commu	nightion load) ( header
	nication ioau) / neauei
Setpoint for the CPU communication load	50 %
<ul> <li>Setpoint for the CPU communication load</li> <li>number of remote connection partners / with PROFINET CBA</li> </ul>	
number of remote connection partners / with PROFINET	50 %
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA</li> </ul>	50 % 32
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for</li> </ul>	50 % 32 30
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET</li> </ul>	50 % 32 30 1 000
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET</li> </ul>	50 % 32 30 1 000 4 000 byte
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>number of internal and PROFIBUS interconnections / with PROFINET CBA / maximum</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> </ul>	50 % 32 30 1 000 4 000 byte 4 000 byte
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>number of internal and PROFIBUS interconnections / with PROFINET CBA / maximum</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> </ul>	50 % 32 30 1 000 4 000 byte 4 000 byte 500 4 000 byte 1 400 byte
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>odata volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>number of internal and PROFIBUS interconnections / with PROFINET CBA / maximum</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / with PROFINET CBA / per connection / maximum</li> <li>performance data / PROFINET CBA / remote interconnection /</li> </ul>	50 % 32 30 1 000 4 000 byte 4 000 byte 500 4 000 byte 1 400 byte 1 400 byte
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>adata volume / of internal and PROFIBUS interconnections / with PROFINET CBA / maximum</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / with PROFINET CBA / per connection / maximum</li> <li>performance data / PROFINET CBA / remote interconnections / in the case of acyclic transmission / with PROFINET CBA</li> </ul>	50 % 32 30 1 000 4 000 byte 4 000 byte 500 4 000 byte 1 400 byte 1 400 byte with acyclic transfer / header 500 ms
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>number of internal and PROFIBUS interconnections / with PROFINET CBA / maximum</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / with PROFINET CBA / per connection / maximum</li> <li>performance data / PROFINET CBA / remote interconnections / maximum</li> </ul>	50 % 32 30 1 000 4 000 byte 4 000 byte 500 4 000 byte 1 400 byte 1 400 byte
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>number of internal and PROFIBUS interconnections / with PROFINET CBA / maximum</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / with PROFINET CBA / per connection / maximum</li> <li>performance data / PROFINET CBA / remote interconnection / maximum</li> <li>performance data / PROFINET CBA / remote interconnection / maximum</li> </ul>	50 % 32 30 1 000 4 000 byte 4 000 byte 500 4 000 byte 1 400 byte 1 400 byte with acyclic transfer / header 500 ms
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>number of internal and PROFIBUS interconnections / with PROFINET CBA / maximum</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / with PROFINET CBA / per connection / maximum</li> <li>performance data / PROFINET CBA / remote interconnection / maximum</li> <li>performance data / PROFINET CBA / remote interconnection / maximum</li> <li>mumber of remote connections to input variables / in the case of acyclic transmission / with PROFINET CBA / maximum</li> <li>number of remote connections to output variables / in the case of acyclic transmission / with PROFINET CBA / maximum</li> </ul>	50 % 32 30 1 000 4 000 byte 4 000 byte 500 4 000 byte 1 400 byte 1 400 byte 300 ms 100
<ul> <li>number of remote connection partners / with PROFINET CBA</li> <li>number of technological functions / with PROFINET CBA / for master or slave</li> <li>number of connections / with PROFINET CBA / for master or slave / total</li> <li>data volume / of the input variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>data volume / of the output variables / with PROFINET CBA / for master or slave</li> <li>number of internal and PROFIBUS interconnections / with PROFINET CBA / maximum</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / of internal and PROFIBUS interconnections / with PROFINET CBA / for master or slave</li> <li>data volume / with PROFINET CBA / per connection / maximum</li> <li>performance data / PROFINET CBA / remote interconnection / maximum</li> <li>performance data / PROFINET CBA / remote interconnection / maximum</li> <li>— update time / of the remote interconnections / in the case of acyclic transmission / with PROFINET CBA / maximum</li> <li>— number of remote connections to output variables / in the case of acyclic transmission / with PROFINET CBA / maximum</li> <li>— number of remote connections to output variables / in the case of acyclic transmission / with PROFINET CBA / maximum</li> <li>— number of remote connections to output variables / in the case of acyclic transmission / with PROFINET CBA / maximum</li> <li>— data volume / as user data for remote interconnections with input variables / in the case of</li> </ul>	50 % 32 30 1 000 4 000 byte 4 000 byte 500 4 000 byte 1 400 byte 1 400 byte 1 400 byte 1 100

interconnections / in the case of acyclic transmission / with PROFINET CBA / per connection / maximum

with PROFINET CBA / per connection / maximum	
performance data / PROFINET CBA / remote interconnection	/ with cyclic transfer / header
<ul> <li>— update time / of the remote interconnections / with cyclical transfer / with PROFINET CBA</li> </ul>	10 ms
<ul> <li>number of remote connections to input variables / with PROFINET CBA / with cyclic transfer / maximum</li> </ul>	200
<ul> <li>number of remote connections to output variables / with cyclical transfer / with PROFINET CBA / maximum</li> </ul>	200
<ul> <li>data volume / as user data for remote interconnections with input variables / with cyclical transfer / with PROFINET CBA / maximum</li> </ul>	2 000 byte
<ul> <li>data volume / as user data for remote interconnections with output variables / with cyclical transfer / with PROFINET CBA / maximum</li> </ul>	2 000 byte
<ul> <li>data volume / as user data for remote interconnections / with cyclical transfer / with PROFINET CBA / per connection / maximum</li> </ul>	450 byte
performance data / PROFINET CBA / HMI variables via PROF	INET / acyclic / header
<ul> <li>— number of connectable HMI stations / for HMI variables / in the case of acyclic transmission / with PROFINET CBA</li> </ul>	3; 2x PN OPC/1x iMap
<ul> <li>update time / of the HMI variables / in the case of acyclic transmission / with PROFINET CBA</li> </ul>	500 ms
<ul> <li>number of HMI variables / in the case of acyclic transmission / with PROFINET CBA / maximum</li> </ul>	200
<ul> <li>— data volume / as user data for HMI variables / in the case of acyclic transmission / with PROFINET CBA / maximum</li> </ul>	2 000 byte
performance data / PROFINET CBA / PROFIBUS proxy functi	onality / header
	Yes
PROFIBUS proxy functionality — number of coupled PROFIBUS devices / with PROFIBUS functionality	16
<ul> <li>data volume / with PROFIBUS proxy functionality / with PROFINET CBA / per connection / maximum</li> </ul>	240 byte; Slave-dependent
Number of connections	
• overall	32
	04
<ul> <li>usable for PG communication</li> </ul>	31
<ul> <li>usable for PG communication</li> <li>— reserved for PG communication</li> </ul>	1
— reserved for PG communication	1
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> </ul>	1 1
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> </ul>	1 1 31
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> </ul>	1 1 31 31 1 1
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> </ul>	1 1 31 31 1 1 31
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> </ul>	1 1 31 31 1 1 31 30
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> </ul>	1 1 31 31 1 1 31 30 0
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> </ul>	1 1 31 31 1 1 31 30 0 0
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> </ul>	1 1 31 31 1 1 31 30 0 0 30
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>usable for S7 basic communication, max.</li> <li>usable for S7 communication</li> </ul>	1 1 31 31 1 1 31 30 0 0 0 30 30 16
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> </ul>	1 1 31 31 1 1 1 31 30 0 0 0 30 16 0
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>reserved for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication</li> </ul>	1 1 31 31 1 1 31 30 0 0 30 16 0 0
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>reserved for S7 communication</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication</li> </ul>	1 1 31 31 1 1 31 30 0 0 30 16 0 16
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>reserved for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> </ul>	1 1 31 31 1 1 31 30 0 0 0 30 16 0 0 16 32
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>reserved for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>total number of instances, max.</li> <li>usable for routing</li> </ul>	1 1 31 31 1 1 31 30 0 0 30 16 0 16
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication, min.</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>reserved for S7 communication</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>total number of instances, max.</li> <li>usable for routing</li> </ul>	1 1 31 31 1 1 31 30 0 0 0 0 30 16 0 0 16 32 X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 14; X2 as PROFINET: 24 max.
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication, min.</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>reserved for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication, max.</li> <li>usable for S7 communication, min.</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>usable for s7 communication, max.</li> </ul>	1 1 31 31 1 1 1 31 30 0 0 0 0 30 16 0 0 16 32 X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 1; X2 as PROFINET: 24 max. 32; Depending on the configured connections for PG/OP and S7 basic communication
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication, min.</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>reserved for S7 basic communication</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>total number of instances, max.</li> <li>usable for routing</li> </ul>	1 1 31 31 1 1 1 30 0 0 0 30 16 0 0 16 32 X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 14; X2 as PROFINET: 24 max. 32; Depending on the configured connections for PG/OP and S7 basic communication Yes
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>usable for routing</li> </ul> S7 message functions Number of login stations for message functions, max. Process diagnostic messages <ul> <li>simultaneously active Alarm-S blocks, max.</li> </ul>	1 1 31 31 1 1 1 31 30 0 0 0 0 30 16 0 0 16 32 X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 1; X2 as PROFINET: 24 max. 32; Depending on the configured connections for PG/OP and S7 basic communication
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>adjustable for S7 communication</li> <li>reserved for S7 communication</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication, max.</li> <li>usable for S7 communication, max.</li> <li>usable for S7 communication, max.</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication, max.</li> <li>usable for routing</li> </ul> S7 message functions Number of login stations for message functions, max. Process diagnostic messages <ul> <li>simultaneously active Alarm-S blocks, max.</li> </ul>	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication</li> <li>adjustable for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>usable for routing</li> </ul> S7 message functions Number of login stations for message functions, max. Process diagnostic messages <ul> <li>simultaneously active Alarm-S blocks, max.</li> </ul>	1         31         31         31         1         1         31         30         0         0         30         16         02         16         32         X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 14; X2 as PROFINET: 24 max.         32; Depending on the configured connections for PG/OP and S7 basic communication         Yes         300         Yes; Up to 2 simultaneously
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>adjustable for S7 communication</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication, min.</li> <li>adjustable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication, max.</li> <li>usable for s7 communication, max.</li> <li>adjustable for S7 communication, max.</li> <li>usable for routing</li> </ul> S7 message functions Number of login stations for message functions, max. Process diagnostic messages <ul> <li>simultaneously active Alarm-S blocks, max.</li> </ul> Test commissioning functions Status block Single step	1         1         31         31         1         1         31         30         0         0         30         16         0         0         16         32         X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max.         14; X2 as PROFINET: 24 max.         32; Depending on the configured connections for PG/OP and S7 basic communication         Yes         300         Yes; Up to 2 simultaneously         Yes
<ul> <li>reserved for PG communication</li> <li>adjustable for PG communication, min.</li> <li>adjustable for PG communication, max.</li> <li>usable for OP communication</li> <li>reserved for OP communication, min.</li> <li>adjustable for OP communication, max.</li> <li>usable for S7 basic communication</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, min.</li> <li>adjustable for S7 basic communication, max.</li> <li>usable for S7 communication</li> <li>reserved for S7 communication</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication, min.</li> <li>adjustable for S7 communication, max.</li> <li>usable for S7 communication, max.</li> <li>usable for S7 communication, max.</li> <li>adjustable for S7 communication, max.</li> <li>usable for routing</li> </ul> S7 message functions Number of login stations for message functions, max. Process diagnostic messages <ul> <li>simultaneously active Alarm-S blocks, max.</li> </ul>	1         31         31         31         1         1         31         30         0         0         30         16         02         16         32         X1 as MPI: max. 10; X1 as DP master: max. 24; X1 as DP slave (active): max. 14; X2 as PROFINET: 24 max.         32; Depending on the configured connections for PG/OP and S7 basic communication         Yes         300         Yes; Up to 2 simultaneously

Status/control variable	Yes
Variables	Inputs, outputs, memory bits, DB, times, counters
<ul> <li>Number of variables, max.</li> </ul>	30
— of which status variables, max.	30
- of which control variables, max.	14
Forcing	
Forcing	Yes
• Forcing, variables	Inputs, outputs
Number of variables, max.	10
Diagnostic buffer	
• present	Yes
<ul> <li>Number of entries, max.</li> </ul>	500
— adjustable	No
— of which powerfail-proof	100; Only the last 100 entries are retained
Number of entries readable in RUN, max.	499
— adjustable	Yes; From 10 to 499
— preset	10
Service data	
can be read out	Yes
Ambient conditions	
Ambient temperature during operation	
• min.	0°0
• max.	0 ℃ 60 ℃
configuration / header	
Configuration software	Ver VEE er histor
• STEP 7	Yes; V5.5 or higher
configuration / programming / header	ees instruction list
Command set	see instruction list
Nesting levels	8
System functions (SFC)	see instruction list
System function blocks (SFB)	see instruction list
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— CFC	Yes
- GRAPH	Yes
— HiGraph®	Yes
Know-how protection	
User program protection/password protection	Yes
Block encryption	Yes; With S7 block Privacy
Dimensions	
Width	40 mm
Height	125 mm
Depth	130 mm
Weights	
Weight, approx.	340 g
	<b>c</b> ]
last modified:	8/16/2023

last modified:

8/16/2023 🖸